



RICK SNYDER
GOVERNOR

State of Michigan
DEPARTMENT OF HUMAN SERVICES
BUREAU OF CHILDREN AND ADULT LICENSING



MAURA D. CORRIGAN
DIRECTOR

June 13, 2012

Holly Piotrowski
11790 North Riggsville
Cheboygan, MI 49721

RE: License #: DG160302816
Piotrowski, Holly
11790 N. Riggsville
Cheboygan, MI 49721

Dear Ms. Piotrowski:

Attached is the Addendum to the Original Licensing Study Report for the above referenced facility.

Please review the enclosed documentation for accuracy and feel free to contact me with any questions. In the event that I am not available and you need to speak to someone immediately, please feel free to contact the local office at (906) 226-4171.

Per MCL 722.113g, this report and any related corrective action plans must be filed in your licensing notebook.

Sincerely,

Jeannie Ellis, Licensing Consultant
Bureau of Children and Adult Licensing
711 W Chisholm
Alpena, MI 49707
(989) 590-0191

enclosure

**MICHIGAN DEPARTMENT OF HUMAN SERVICES
BUREAU OF CHILDREN AND ADULT LICENSING
ADDENDUM TO ORIGINAL LICENSING STUDY REPORT**

I. IDENTIFYING INFORMATION

License #:	DG160302816
Licensee Name:	Holly Piotrowski
Licensee Address:	11790 North Riggsville Cheboygan, MI 49721
Licensee Telephone #:	(231) 597-9754
Administrator/Licensee Designee:	N/A
Name of Facility:	Piotrowski, Holly
Facility Address:	11790 N. Riggsville Cheboygan, MI 49721
Facility Telephone #:	(231) 597-9754
Capacity:	12
Program Type:	CHILD CARE GROUP HOME (CAPACITY 7-12)

II. Purpose of Addendum

The licensee would like to have the new child care room located off her kitchen approved as child use space.

III. Methodology

- 05/08/12- Contact Document Received- Modification Request
- 05/29/12- Inspection Complete- On-site

IV. Description of Findings and Conclusions

The Licensee has had a new child care room built off her kitchen in what used to be her attached garage. The room is 18 feet by 20 feet for a total of 360 square feet. This room will accommodate 10 children.

There are three exits remote of each other. Two exits are through doors on opposite ends of the room. Both of these doors exit outside at grade level. There is a third exit into the kitchen.

There are no hazards or hazardous materials in this room. The outlets are all covered with child proof safety covers. The room has a smoke detector and carbon monoxide detector. A fire extinguisher is accessible for use in the kitchen and the licensee stated she also intends on mounting a fire extinguisher in this child care room as well.

There is a bathroom located in the northeast corner of the room. The water temperature in this bathroom was 106 degrees Fahrenheit. There are no hazards located in this bathroom. The outlets are all covered with child proof safety covers.

V. Recommendation

I recommend the approval of the child care room located off the kitchen as an approved child care use space.

Jeannie C. Ellis

June 13, 2012

Jeannie Ellis
Licensing Consultant

Date

Approved By:

Rose A. Rafferty-Aguirre

June 13, 2012

Rose A. Rafferty-Aguirre
Area Manager

Date