



RICK SNYDER
GOVERNOR

STATE OF MICHIGAN
DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS
LANSING

SHELLY EDGERTON
DIRECTOR

August 17, 2016

Christine Ford
2113 Daylor Dr. NE
Grand Rapids, MI 49525

RE: License #: DG410377888
Ford Christine
2113 Daylor Dr. NE
Grand Rapids, MI 49525

Dear Ms. Ford:

Attached is the Addendum to the Original Licensing Study Report for the above referenced facility.

Please review the enclosed documentation for accuracy and contact me with any questions. In the event that I am not available and you need to speak to someone immediately, please contact the local office at (616) 356-0100.

Per MCL 722.113g, this report must be filed in your licensing notebook.

Sincerely,

A handwritten signature in cursive script, appearing to read "Debra Purdom".

Debra Purdom, Licensing Consultant
Bureau of Community and Health Systems
Unit 13, 7th Floor
350 Ottawa, N.W.
Grand Rapids, MI 49503
(616) 916-5206

enclosure

**MICHIGAN DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS
BUREAU OF COMMUNITY AND HEALTH SYSTEMS
ADDENDUM TO ORIGINAL LICENSING STUDY REPORT**

I. IDENTIFYING INFORMATION

License #:	DG410377888
Licensee Name:	Christine Ford
Licensee Address:	2113 Daylor Dr. NE Grand Rapids, MI 49525
Licensee Telephone #:	(616) 805-1482
Name of Facility:	Ford Christine
Facility Address:	2113 Daylor Dr. NE Grand Rapids, MI 49525
Facility Telephone #:	(616) 805-1482
Capacity:	12
Program Type:	CHILD CARE GROUP HOME (CAPACITY 7-12)

II. Purpose of Addendum

Christine Ford has remodeled her basement and installed egress windows. She requests department approval to use the family room in the basement for child care.

III. Methodology

08/17/2016 – Modification request received

08/17/2016 – Inspection completed onsite

IV. Description of Findings and Conclusions

The basement has three bedrooms, each with an egress window, a bathroom with shower, and a family room. The bedrooms will not be used and are not approved. The stairs from the main floor and the egress window in the bedroom behind the stairs provide exiting and are remote from each other. The identified emergency exit window opens quickly and easily. The family room in the basement will be used and is approved for additional use space.

The main floor was approved previously and continues to be used for child care.

V. Recommendation

I recommend approval of the family room in the basement as additional use space in this child care home.



08/17/2016

Debra Purdom
Licensing Consultant

Date