



GRETCHEN WHITMER
GOVERNOR

STATE OF MICHIGAN
DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS
LANSING

ORLENE HAWKS
DIRECTOR

April 12, 2019

Jennifer Dillenbeck
369 Tannery Drive
Coloma, MI 49038

RE: License #: DG110313736
Dillenbeck, Jennifer
369 Tannery Drive
Coloma, MI 49038

Dear Ms. Dillenbeck:

This letter is a follow-up to the Department's findings regarding the interim inspection conducted at your home on 04/10/2019. The purpose of this inspection was to determine compliance with applicable licensing statutes and administrative rules for Family and Group Child Care Homes.

The violations that were found are:

R 400.1944 **Smoke detectors; fire extinguishers.**

(1) Operable smoke detectors approved by a nationally recognized testing laboratory shall be installed and maintained on each floor of the home, including the basement, and in all sleeping areas and bedrooms used by children in care.

Smoke detectors have not been installed in all sleep areas.

The Department provides technical assistance to meet the licensing requirements and consultation to improve services.

Please contact me with any questions. In the event that I am not available and you need to speak to someone immediately, please contact the local office at (616) 356-0183.

Per MCL 722.113g, this report and any related corrective action plans must be filed in your licensing notebook.

Sincerely,

A handwritten signature in blue ink, appearing to read 'Tiara McKay', written in a cursive style.

Tiara McKay, Licensing Consultant
Child Care Licensing Division
322 E. Stockbridge Avenue
Kalamazoo, MI 49001
(269) 615-5758