



GRETCHEN WHITMER
GOVERNOR

STATE OF MICHIGAN
DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS
LANSING

ORLENE HAWKS
DIRECTOR

June 6, 2019

Cynthia Killingsworth
607 Southworth Terrace
Kalamazoo, MI 49048

RE: License #: DG390314132
Killingsworth, Cynthia
607 Southworth Terrace
Kalamazoo, MI 49048

Dear Ms. Killingsworth:

This letter is a follow-up to the Department's findings regarding the interim inspection conducted at your home on 06/04/2019. The purpose of this inspection was to determine compliance with applicable licensing statutes and administrative rules for Family and Group Child Care Homes.

The violations that were found are:

R 400.1944 **Smoke detectors; fire extinguishers.**

(3) A home shall have at least 1 functioning multipurpose fire extinguisher, with a rating of 2A-10BC or larger, properly mounted not higher than 5 feet from the floor to the top of the fire extinguisher, on each floor level approved for child use.

The fire extinguisher in the basement was empty and needs recharged or replaced.

Violations were identified at the time of the inspection. You have provided an acceptable written corrective action plan.

The Department provides technical assistance to meet the licensing requirements and consultation to improve services.

Please contact me with any questions. In the event that I am not available and you need to speak to someone immediately, please contact the local office at (616) 356-0183.

Per MCL 722.113g, this report and any related corrective action plans must be filed in your licensing notebook.

Sincerely,



Julia Majka, Licensing Consultant
Bureau of Community and Health Systems
322 E. Stockbridge Ave
Kalamazoo, MI 49001
(269) 615-6039