



GRETCHEN WHITMER
GOVERNOR

STATE OF MICHIGAN
DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS
LANSING

ORLENE HAWKS
DIRECTOR

August 21, 2019

Sharday Williams
330 Park Avenue
Berrien Springs, MI 49103

RE: License #: DF110394034
Sharday Williams
330 Park Avenue
Berrien Springs, MI 49103

Dear Ms. Williams:

This letter is a follow-up to the Department's findings regarding the interim inspection conducted at your home on 08/20/2019. The purpose of this inspection was to determine compliance with applicable licensing statutes and administrative rules for Family and Group Child Care Homes.

The violations that were found are:

R 400.1944 **Smoke detectors; fire extinguishers.**

(1) Operable smoke detectors approved by a nationally recognized testing laboratory shall be installed and maintained on each floor of the home, including the basement, and in all sleeping areas and bedrooms used by children in care.

A smoke detector has not been placed in one sleeping area.

R 400.1944 **Smoke detectors; fire extinguishers.**

(3) A home shall have at least 1 functioning multipurpose fire extinguisher, with a rating of 2A-10BC or larger, properly mounted not higher than 5 feet from the floor to the top of the fire extinguisher, on each floor level approved for child use.

Fire extinguishers were not mounted on either level approved for child use.

Violations were identified at the time of the inspection. You have provided an acceptable written corrective action plan.

The Department provides technical assistance to meet the licensing requirements and consultation to improve services.

Please contact me with any questions. In the event that I am not available and you need to speak to someone immediately, please contact the local office at (616) 356-0183.

Per MCL 722.113g, this report and any related corrective action plans must be filed in your licensing notebook.

Sincerely,

A handwritten signature in blue ink, appearing to read 'Tiara McKay', written in a cursive style.

Tiara McKay, Licensing Consultant
Child Care Licensing Division
322 E. Stockbridge Avenue
Kalamazoo, MI 49001
(269) 615-5758