



GRETCHEN WHITMER
GOVERNOR

STATE OF MICHIGAN
DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS
LANSING

ORLENE HAWKS
DIRECTOR

November 27, 2019

Connie Brown
13541 Burton Street
Oak Park, MI 48237

RE: License #: DF630311826
Brown, Connie
13541 Burton Street
Oak Park, MI 48237

Dear Ms. Brown,

An interim inspection was conducted at your home on 11/27/19. The purpose of this inspection was to determine compliance with applicable licensing statutes and administrative rules for Family and Group Child Care Homes.

There was one violation.

R 400.1943 **Exit and escape requirements for each floor level used by children.**

(7) Doors located in a required path of escape must be readily openable from the side of egress without the use of a key or special knowledge. Double cylinder locks, key-operated locks, and similar devices are not allowed on any door in a required path of escape.

The side door used for egress has a key-operated deadbolt lock.


On 11/27/2019, you provided an acceptable written corrective action plan.

You can find a copy of this inspection letter and any associated corrective action plans on our [website](#) under [Statewide Search for Licensed Child Care Centers and Homes](#). A description of when inspection letters are completed can be found under [Overview of Licensing Reports](#).

Please contact me with any questions. If I am unavailable and you need to speak to someone immediately, please contact the local office at (248) 975-5053.

Per MCL 722.113g, this report and any related corrective action plans must be filed in your Licensing Notebook.

Sincerely,

A handwritten signature in black ink, appearing to read "Cynthia Jalynski". The signature is written in a cursive style with a large initial "C".

Cynthia Jalynski, Licensing Consultant
Bureau of Community and Health Systems
51111 Woodward Avenue, Suite 4B
Pontiac, MI 48342
(248) 860-3222